



Transatlantic Workshop on Electric Vehicles and Grid Connectivity

G4V – grid-for-vehicles Project

Thomas Theisen, RWE Rheinland Westfalen Netz AG

Project coordinator

17 November 2010

Brussels

The research leading to these results has received funding from the European Union Seventh Framework Programme (FP7/2007 – 2013) under grant agreement No. 241295.

CHALMERS



**Imperial College
London**



Overview – the G4V-project


Project duration: Jan 2010 – June 2011




time-horizon: 2030

Key – Question:

What needs to be started **now** in order to enable a mass market of EV?



- technical issues
- legal framework
- business model
- customer convenience
- environmental aspects




Recommendations


The G4V consortium



12 partners from eight countries



Influencing Parameters




- market penetration (subsidies ?)
- regional distribution
- temporal distribution
- directionality (uni/bi)
- kind of vehicle (BEV/PHEV)
- kind of battery (Li-Ion?)
- battery capacity (1kWh - 35kWh, usable percentage ?)
- battery exchangeability (yes/no)
- energy demand (approx. 6kWh/d, log-normal distribution)
- connection power (3.7kW - 40kW)
- market access regulation
- ...


Definition of Szenario-worlds



How could the development in the European electricity sector look like?



Overview about Control strategies




- Main objectives:
 - Integration Renewables
 - LV-grid – congestion management
 - Exploitation of EV's flexibilities







„G4V Impact Assessment Approach“



- agent based
- geographically referenced
- high time resolution (15min)
- long duration (2010-2030+)



„G4V Impact Assessment Approach“




„EU-27 Impact Assessment“




North, South,
Central Europe


Urban, Rural,
Suburban




Extrapolation of
local results to
national level



Extrapolation to
EU-27 impacts



Exemplary results - Probabilistic load flow



Specs:

- suburban grid: 630kVA transformer
- 250 households
- Energy consumption 2000-4000kWh/a
- Radial distribution grid
- Battery capacity 35 kWh
- Penetration rate: 12,5%

- only a few transformer overloads
- Necessary to include a safety margin (probability of occurrence) into grid assessment




V2G for Aggregation



Aggregation

- technical requirements (ICT, Charger, ...)
- load flow calculations and impact on grid-levels (LV, MV, HV)
→ interdependencies!
- business case (reserve power market)



**Frequency control: V2G vs generators?
→ Comparison needs to be elaborated!**



Thank you!

also please visit: www.g4v.eu

Contact:

RWE Rheinland Westfalen Netz AG
New Technologies

Thomas Theisen

+49 201 12 29387

thomas.theisen@rwe.com